PEI/RP900-21

APPENDIX A-2: SAMPLE FORM "OTHER" SUMP INSPECTION CHECKLIST

Go to www.pei.org/RP900 for an electronic version of this form.

ID#:	ANNUAL "OTHER" SUMP INSPECTION CHECKLIST				Date:			
Category	Description	PI	EI/RP900	N/A	Tank 1	Tank 2	Tank 3	Tank 4
Other Sump. Describe location or function (e.g., suction piping, tank manhole) on this row:		7	7.6					
Other Sump	Any water or product removed and disposed of properly	7	7.6.4					
	Visible piping and fittings show no signs of leaking	7	7.6.1					
	Piping in good condition	7	7.6.2					
	Sump free of trash and debris	7	7.6.5					
	Sump is free of cracks, holes, bulges, or other defects		7.6.6					
	Penetration fittings intact and secured		7.6.7					
	Junction box(es) have covers, not corroded; conduit and intrinsically safe wiring in good condition		7.6.8					
	Flexible connectors not frayed, twisted, kinked or bent beyond manufacturer specifications		7.6.9					
	Piping interstitial space open to the sump (open double-walled piping system only)		7.6.20					
	Piping interstitial space closed to the sump (closed double-walled piping system only)		7.6.22					
	Sump lid, gasket and seals present and in good condition		7.6.23					
	Manhole cover at grade in good condition, does not touch sump cover, all bolts present, handles and lift mechanism in good condition (as applicable)		7.6.24					
Single-Walled Other Sump	Single-walled sump tested for integrity every 3 years TEST DATE	:: 7	7.6.18					ı
Double-Walled Other Sump	If not continuously monitored or inspected annually, double-walled sump tightness tested every 3 years TEST DATE	:: 7	7.6.19					ı
DESCRIBE ANY	DEFICIENCIES HERE:							